## Domestic Landlord Gas Safety Record #20191-A-0036

## Rekan Kingji



		Ins	taller/Compa	any Details				Customer/Agent/Landlord Details							Installation Site Details					
Name	:	Reka	Rekan Kingji						Fenix Properties					Name:						
Engin	eer Nam	e: Reka	Rekan Kingji					Address:		976 Uxbridge Road UB8					s:	52 Ha	52 Hatfield Court Canberra Drive UB5 6JW			
Gas S No:	afety Re	g. 5871	60				Telephone:		Mobile		e: 07576600994		Telephone:			Mobile:				
Addre	ss:	30 A	30 Apprentice Gardens UB5 6GP																	
Telephone:		0788	2467282	Mobile: 07882467282		2														
#	Туре	Applianc Location		Model	Landlord's Appliance	Flue Type	Appliance Inspe		Safety Devices Operatin Correctly		Ventilation Provision Satisfactory?		Operating Pressure/Heat input	Flue Performance Checks		Visual Condition Of Flue?	Termination Satisfactory?	Was Appliance Serviced?	Is Applianc Safe To Use?	
22732	Combi Boiler	Kitchen	Worcester	Greenstar R25 HE	Yes	RS	Yes	N	No Yes		Yes	3	21.5 kW	Pass		Yes	Yes	No	Yes	
1st reading/min									2nd reading/max					3rd reading/ign						
	#		СО		CO2	CO2			СО	ю		2 Ratio		СО		co	CO2		Ratio	
	2273	2																		
#			Faults	Found	und			Rectification Work						Label And Warning Notice						
Final Check Results									Sign Off											
Gas tightness satisfactory Yes									Sign Off Date: 17-07-2019					Next Safety Check Date: 17-07-2020						
Equipotential bonding Yes									Received By Signature						Issued By Signature					
Emergency control valve accessible Yes								Na					Asma		Engineer: Rekan Kingji					
Gas installation pipework visual inspection Yes									Position			Tenant								
CO al	arm pres	ent & workir	g			Yes														
Smok	e alarm p	oresent & wo	rking			Yes								h 1						
In accordance with Gas Safety (Installation and Use) Regulation																	fun,			

