Energy performance certificate (EPC)

Flat 9 2, Newsome Road HUDDERSFIELD HD4 6NY Energy rating

Valid until: 5 April 2027

Certificate number: 8107-5155-0129-4007-4433

Property type Top-floor flat

Total floor area 19 square metres

Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be C.

<u>See how to improve this property's energy performance.</u>



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Sandstone or limestone, as built, insulated (assumed)	Good
Roof	Pitched, insulated (assumed)	Good
Window	Fully double glazed	Good
Main heating	Community scheme	Good
Main heating control	Flat rate charging, TRVs	Average
Hot water	Community scheme	Good
Lighting	Low energy lighting in 67% of fixed outlets	Good
Floor	(another dwelling below)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 220 kilowatt hours per square metre (kWh/m2).

Environmental impact of this property		This property produces	0.7 tonnes of CO2
This property's current environmental impact rating is B. It has the potential to be B.		This property's potential production	0.7 tonnes of CO2
Properties are rated in a scale from A to G based on how much carbon dioxide (CO2) they produce.		By making the recommend could reduce this property's 0.0 tonnes per year. This wenvironment.	s CO2 emissions by
Properties with an A rating	produce less CO2		
than G rated properties.		Environmental impact ratin assumptions about average	e occupancy and
An average household produces	6 tonnes of CO2	energy use. They may not consumed by the people liv	

Improve this property's energy performance

By following our step by step recommendations you could reduce this property's energy use and potentially save money.

Carrying out these changes in order will improve the property's energy rating and score from C (78) to C (78).

Step	Typical installation cost	Typical yearly saving
1. Low energy lighting	£5	£6

Paying for energy improvements

Find energy grants and ways to save energy in your home. (https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property	£237
Potential saving	£7

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The potential saving shows how much money you could save if you <u>complete each</u> <u>recommended step in order</u>.

For advice on how to reduce your energy bills visit <u>Simple Energy Advice</u> (https://www.simpleenergyadvice.org.uk/).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Type of heating	Estimated energy used	
Space heating	180 kWh per year	
Water heating	1821 kWh per year	

Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name Conrad Wass Telephone 07974 269980

Email <u>conrad.wass@gmail.com</u>

Accreditation scheme contact details

Accreditation scheme Elmhurst Energy Systems Ltd

Assessor ID EES/020092 Telephone 01455 883 250

Email <u>enquiries@elmhurstenergy.co.uk</u>

Assessment details

Assessor's declaration

Date of assessment

Date of certificate

Type of assessment

No related party
5 April 2017
6 April 2017

RdSAP